

LINCOLN CHARTER TOWNSHIP MOBILE FOOD VENDOR

FIRE DEPARTMENT INSPECTION CHECKLIST

SECTION	QUESTION	Result
Portable Fire Extinguishers	Class K extinguisher present and annually serviced where cooking equipment involves solid fuels, vegetable, or animal oils and fats?	
Portable Fire Extinguishers	Portable (2A:20BC) extinguisher present and annually serviced?	
Exhaust Hood (type I)	Is a type I hood present where cooking equipment will produce grease-laden vapors?	
Exhaust Hood (type I)	Is the hood protected by an approved automatic extinguishing system?	
Exhaust Hood (type I)	Does the automatic extinguishing system also contain a means of manual activation?	
Exhaust Hood (type I)	Has the extinguishing system been serviced and tagged by contractor?	
Exhaust Hood (type I)	Have the fusible links and/or sprinkler heads been replaced annually, at minimum?	
Exhaust Hood (type I)	Has the exhaust system been cleaned in accordance with Section 607?	
Interior	Exits clear?	
Interior	Storage neat and orderly?	
Interior	Rubbish, oily rags, and waste material properly stored?	
Hazardous Materials	Compressed gas cylinders secured?	
Hazardous Materials	Spare tank covers installed?	
Electrical Features	Appliances and fixtures in good condition?	
Electrical Features	Proper wiring and connections?	
Electrical Features	Extension cords properly used?	
Electrical Features	Multiplug adapters properly used?	
Electrical Features	Electrical panel(s) has proper clearances?	
Electrical Features	Are space heater(s) properly used and installed	
LP/CNG System	Maximum aggregate capacity 200lbs or less? (LP Systems)	
LP/CNG System	Are containers securely mounted and restrained to prevent movement?	
LP/CNG System	Is the gas system piping, including valves and fittings, adequately protected to prevent tampering, impact damage, and damage from vibration?	
LP/CNG System	Is a listed LP alarm present? (LPG Systems)	
LP/CNG System	Maximum aggregate capacity 1,300 lbs or less? (CNG Systems)	
LP/CNG System	Is a listed explosive gases / CO alarm present?	
Inspection Notes	Inspection Notes	